
efectorioo

IM0010

IME2020-FBOA **Inductive sensors**





Made in Germany

Product characteristics					
Inductive sensor					
Rectangular, plastics	Rectangular, plastics				
Terminals	Terminals				
Sensing range 20 mm; [nf] non-flush mountable					
Electrical data					
Electrical design		AC/DC			
Operating voltage	[V]	20250 AC/DC			
Protection class		II			
Reverse polarity protection		no			
Outputs					
Output function		normally open / closed programmable			
Voltage drop	[V]	< 6.5 AC / < 6 DC			
Minimum load current	[mA]	5			
Leakage current	[mA]	< 2.5 (250 V AC) / < 1.3 (110 V AC) / < 0.8 (24 V DC)			
Current rating					
- Current rating (continuous)	[mA]	350 AC (50 °C) / 250 AC (80 °C) / 100 DC			
- Current rating (peak)	[mA]	î: 2.2 A (20 ms / 0.5 Hz)			

Short-circuit proof		no
Overload protection		no
Switching frequency	[Hz]	20 AC / 55 DC
Range		
Sensing range	[mm]	20
Real sensing range (Sr)	[mm]	20 ± 10 %
Operating distance	[mm]	016.2
Accuracy / deviations		
Correction factors		mild stool = 1 / stainless stool approx 0.7 / brass approx 0.4 / Al approx 0.2 / Cu

Accuracy / deviation	IS .	
Correction factors		mild steel = 1 / stainless steel approx. 0.7 / brass approx. 0.4 / Al approx. 0.3 / Cu approx. 0.2
Hysteresis	[% of Sr]	115
Switch-point drift	[% of Sr]	-1010


efectorioo





[°C]		-2580			
		IP 65			
	EN 60947-5-2 EN 55011:	class B			
'ears]		604			
		non-flush mountable			
		PPE			
[kg]		0.183			
Displays / operating elements					
LED		yellow			
	terminals up to 2.5 mm	$^{\mathrm{2}}$; cable diameter 713 mm, cable gland M20 x 1	5		
	[kg]	EN 60947-5-2 EN 55011: [ears]	EN 60947-5-2 Class B God		

Wiring



Note: miniature fuse to IEC60127-2 sheet 1,

≤ 2 A (fast acting)

Remarks		
Remarks		Recommendation: check the unit for reliable function after a short circuit. 5 positions of the active zone possible
Pack quantity	[piece]	1

 $ifm\ electronic\ gmbh\ \bullet\ Friedrichstraße\ 1\ \bullet\ 45128\ Essen\ -\ We\ reserve\ the\ right\ to\ make\ technical\ alterations\ without\ prior\ notice.\ -\ GB\ -\ IM0010\ -\ 06.03.2003$